

CSA STANDARD F280-12 COMPLIANCE

NBC 2015: 9.33.5.1.; 9.36.3.2. & 9.36.5.15; NBC 2020: 9.33.5.1.; 9.36.3.2.; 9.36.5.15 (5); 9.36.8.9. (1);

CSA F280-12
Form Set Ver 24.10

These documents issued for the use of _____
and may not be used by any other persons without authorization. Documents for permit and/or construction are signed in red.

PROJECT # _____

BUILDING LOCATION

Model: _____ 3	Site: _____ 6
Address: _____ 4	Lot: _____ 7
City & Province: _____ 5	Postal Code: _____ 8

COMPLIANCE

(See page 2 for input summary and page 3 for room by room values)

Submittal is for: Whole house Room by Room Units: Imperial Metric

HEATING

Minimum Heating Capacity: _____ btuh (total building heat loss as per 5.2.7) _c

5.3.1 The total heat output capacity of all heating systems installed in a building shall not be less than 100% of the total building heat loss as determined in Clause 5.2.7.

5.3.2 The combined heating delivery of the heating systems that serve a room or space shall not be less than 100% of the space heat loss, as determined in Clause 5.2.6.. (If room by room submittal, see page 2 for individual space heating requirements)

COOLING

Nominal Cooling Capacity: _____ btuh (Nominal Cooling Capacity as per 6.3.1) _d

Minimum Cooling Capacity: _____ btuh _e **Maximum Cooling Capacity:** _____ btuh _f

6.3.2 Except as provided in Clause 6.3.3., the cooling system capacity shall not be less than 80% of the nominal cooling capacity for the building, as determined in Clause 6.3.1.. In no case shall it be less than the nominal cooling capacity of the building minus 1800 W (0.51 tons)

6.3.3 Where the cooling system is added to an existing heating system, it's capacity in Watts shall not exceed 18 times the capacity of the air-handling capacity of the existing system in L/s. (Cooling capacity in Tons not more than 1.0 per 400 CFM of air handling capacity)

6.3.4 Except for ground-source and water source heat pumps used for cooling, and as permitted in Clause 6.3.5, the installed cooling capacity shall not exceed 125% of the nominal cooling capacity for the building, as determined in Clause 6.3.1.

6.3.5 If the nominal cooling system capacity for the building, as determined in Clause 6.3.1. is less than 6,000 W (1.7 tons), the installed cooling system capacity may exceed the nominal cooling system capacity for the building by up to 1750 W (0.49 tons).

ATTACHED DOCUMENTS

Design Summary _g Room by Room Results _h Other: _____ _i

Other: _____ _i

Notes: _____ _j

CALCULATIONS PERFORMED BY

Name: _____ 55	Designers Signature, Stamp Imprint or other certification mark	I, _____ have reviewed and take responsibility for the design work described in this document & I am qualified in the appropriate categories. ₆₃
Company: _____ 56		Accreditation Reference 1 ₆₄
Address: _____ 57		Accreditation Reference 2 ₆₅
City & Prov.: _____ 58		Issued for: _____ (date) ₆₆
Postal Code: _____ 59		Issued for: _____ (date) ₆₇
Phone: _____ 60		
Fax: _____ 61		
E-mail: _____ 62		

Page: 1 of

Area for Authority Having Jurisdiction info



CSA F280-12 INPUT SUMMARY

CSA F280-12
Form Set Ver 24.10

These documents issued for the use of _____
and may not be used by any other persons without authorization. Documents for permit and/or construction are signed in red.

PROJECT #

BUILDING LOCATION

Model: _____ 3	Site: _____ 6	Lot: _____ 7
Address: _____ 4	City/ Prov _____ 5	Post. Code: _____ 8

CALCULATION BASED ON (See Following Page For Results)

Dimensional Info Based On: _____ 9		
Attachment: _____ 10	Front Facing: _____ 16	Assumed? _____ 17
# of Stories: _____ 11	Air Tightness: _____ 18	Assumed? _____ 19
Weather Location: _____ 12	Internal Shading: _____ 21	Assumed? _____ 21a
Wind Exposure, Site: _____ 20	Occupants: _____ 22	Assumed? _____ 22a
Wind Sheltering, Building _____ 20a	Ventilated? Yes/No _____ 13	HRV/ERV? Yes/No _____ 14
Units: <input type="checkbox"/> Imperial <input type="checkbox"/> Metric 23	ASE %: _____ 15	ATRE %: _____ 15a

HEATING DESIGN CONDITIONS

COOLING DESIGN CONDITIONS

Outdoor Temp: _____ 24	Indoor Temp: _____ 25	Mean Soil Temp: _____ 26	Outdoor Temp: _____ 27	Range: _____ 29
Soil Conductivity _____ 26a	Water Table Depth: _____ 26b	Slab Fluid Temp: _____ 26c	Indoor Temp: _____ 28	latitude: _____ 30

ABOVE GRADE WALLS

BELOW GRADE WALLS

Style A: _____ 31	Style A: _____ 34
Style B: _____ 32	Style B: _____ 35
Style C: _____ 33	Style C: _____ 36

CEILINGS

FLOORS ON SOIL

Style A: _____ 40	Style A: _____ 37
Style B: _____ 41	Style B: _____ 38
Style C: _____ 42	Style C: _____ 39

WINDOWS

EXPOSED FLOORS

Style A: _____ 49	Style A: _____ 43
Style B: _____ 50	Style B: _____ 44
Style C: _____ 51	Style C: _____ 45

SKYLIGHTS

DOORS

Style A: _____ 52	Style A: _____ 46
Style B: _____ 53	Style B: _____ 47
Style C: _____ 54	Style C: _____ 48

Issued: _____
67

Page: **2** of

Area for 5 i h cf]m\ Uj]b[>i f]gX]W]cb`bZ



ROOM by ROOM CALCULATION RESULTS

CSA F280-12
Form Set Ver 24.10

These documents issued for the use of _____
and may not be used by any other persons without authorization. Documents for permit and/or construction are signed in red.

PROJECT #

2

BUILDING LOCATION

Model: _____ <small>3</small>	Site: _____ <small>6</small>	Lot: _____ <small>7</small>
Address: _____ <small>4</small>	City/ Prov _____ <small>5</small>	Post. Code: _____ <small>8</small>

CALCULATION RESULTS - ROOM by ROOM

#	Room Name <small>71</small>	Heating (Btu/h) <small>72</small>	Cooling (Btu/h) <small>73</small>
1			
2			
3			
4			
5			
6			
7			
8			
9			
10			
11			
12			
13			
14			
15			
16			
17			
18			
19			
20			
21			
22			
23			
24			
25			
26			
27			
28			
29			
30			
31			
32			
33			
34			
35			
36			
37			
38			
39			

Ventilation Loss (if separate) <small>74</small> & Latent Gain (if separate, value or multiplier) <small>75</small>	Btu/h		Btu/h
Total Building Loss (5.2.7) & Nominal Cooling Capacity (6.3.1.)	Btu/h		Btu/h
See page 1 for heating & Cooling System Capacity Limits	issued: _____ <small>67</small>	Page:	3 of 3

Area for '5 i h cf]m\ Uj]b[' > i f]gX]W]cb' -bZ



63